

Number	17-003829-PR04 (NW-A01-02-en-01)
Owner	DOBROPLAST FABRYKA OKIEN sp.z o.o. Stary laskowiec 4 18-300 Zambrow Poland
Product	Tilt and turn casement door
Designation	Shipping name: P-LINE <sup>*)</sup>
Details	Manufacturer DOBROPLAST FABRYKA, OKIEN sp.z o.o. - Zambrow; Material Polyvinyl Chloride unplasticized (PVC-U); Opening direction DIN left, inward opening; Overall dimensions (W x H) 2420 mm x 1170 mm
Special features	<sup>*)</sup> According to the information provided by the manufacturer, the used profiles are taken from company Rehau, System Rehau Synego MD.

### Result

Air permeability according to EN 12207:2016-12



**Class: 4**

Resistance to wind load according to EN 12210:2016-03



**Class: C2/B2**

Watertightness according to EN 12208:1999-11



**Class: 9A**

### Basis <sup>\*)</sup>

EN 14351-1:2006+A2:2016-09

<sup>\*)</sup> and corresponding national versions  
e.g. DIN EN)

Test report: 17-003829-PR04 PB-  
A01-02-de-01

### Representation



### Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

### Validity

There is no time limit.  
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

08.03.2018



Thomas Stefan, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Component Testing



Maximilian Denk  
Operating Testing Officer  
Building Component Testing

Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: A9F-C9E1C