

Classification Report

Number	17-003829-PR01 (NW-A01-02-en-01)
Owner	DOBROPLAST FABRYKA OKIEN sp.z o.o. Stary laskowiec 4 18-300 Zambrow Poland
Product	Tilt and turn window
Designation	Shipping name: P- LINE ^{*)}
Details	Manufacturer DOBROPLAST FABRYKA, OKIEN sp.z o.o. - Zambrow; Material Polyvinyl Chloride unplasticized (PVC-U); Opening direction DIN left, inward opening; Overall dimensions (W x H) 1524 mm x 2364 mm
Special features	^{*)} According to the information provided by the manufacturer, the used profiles are taken from company Rehau, System Rehau Synego MD.

Result

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C2/B2

Watertightness according to EN 12208:1999-11



Class: 8A

Basis ^{*)}

EN 14351-1:2006+A2:2016-09
^{*)} and corresponding national versions
e.g. DIN EN)

Test report: 17-003829-PR01 PB-
A01-02-de-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

08.03.2018



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Maximilian Denk
Operating Testing Officer
Building Component Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 8C2-FD14F